

CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

Certificate num. Registration date Version Valid until

afp - 3194

26-Oct-2017

Number Issue date 4-Apr-2024

30-Apr-2025

Page 1 of 2

Product designation

FirePro, Model FP240V, 240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Altamonte Pty Ltd

138 – 140 Bayfield Rd East, BAYSWATER NORTH, VIC, AUSTRALIA, 3153

Registrant

Siterwell Electronics Co., Limited

No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

Producer

Siterwell Electronics Co., Limited

No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

Conformance criteria and evaluation

The FirePro, Model FP240V, 240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

issued by

Kaj Loh

Executive Officer - ActivFire Scheme





Schedule to

Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 3194	26-Oct-2017	Number 7	Issue date 4-Apr-2024	30-Apr-2025	Page 2 of 2

Producer's description

The FirePro, Model FP240V, 240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm is intended for use in domestic and residential dwellings. The 9Vdc battery is user replaceable.

This smoke alarm is interconnectable for up to 12 units.

The smoke alarm operates according to the principle of light scattering. Inside the measuring chamber, which is protected against external light by a black plastic labyrinth, a light emitter and a light receiver are mounted so that no direct light from the emitter can reach the receiver while aerosol is absent in the chamber.

If smoke particles enter the measuring chamber, the light pulse from the light emitter will be scattered by the smoke particles and can thus reach the light receiver. The electronics assess the light incidence and will activate an alarm (both visual and audible) if a predetermined threshold value is exceeded.

This unit is circular in shape and is approximately 140 mm diameter with a height of 43 mm.

Technical specification

The following details are a representative extract of the technical specification for the FirePro, Model FP240V, 240 Vac powered with 9 Vdc battery backup, hush/silencing facility, interconnectable, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Sensor		Photoelectric		
Power		220~240 Vac 50Hz with 9 Vdc battery backup (replaceable)		
Battery replacement		Voltage: 9 Vdc (Carbon Zinc, Alkaline. Lithium battery)		
		Gold Peak: GP1604S (Carbon Zinc Battery)		
		Gold Peak: GP1604A (Alkaline Battery)		
		Raymax: 6LR61 (Alkaline Battery)		
		EVE: CR9V/P (Lithium battery)		
Operation current		< 100mA (alarm)		
Alarm volume		85 dB(A) at 3 meters		
Alarm sensitivity		0.127~0.208 dB/m		
Silence time		approx. 8 minutes		
Interconnection		Up to 12 units		
Smoke alarm device sound pattern:		ISO 8201		
Dimensions (approx.)	Diameter	140 mm		
	Height	43 mm		

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference			Date issued		
Ident. type	Ident.	Title / description	(or date validated)	Source	
Report	XF3160/R1	Evaluation for Conformity of the FirePro Model FP240V Photoelectric Smoke Alarm to the requirements of AS 3786:2014 +A1:2015	26-Oct-2017	CCUPO Fire Contents	
	XF3048/R2	Evaluation for Conformity of the Siterwell Electronics Co. Limited Model GS517E and GS518E Photoelectric Smoke Alarms to the requirements of AS 3786-2014 +A1:2015	18-May-2017	CSIRO, Fire Systems Laboratory, AU	
Document No.	RD-517E-39-001 Version: D	Smoke Alarm User Manual Model number: FP240V Ref: ST517E	28-April-2017	Siterwell Electronics Co., Limited, CN	