



# Certificate of Conformity

Certificate num.	Registration date	Version	Issue date	Valid until	Page 1 of 2
<b>afp - 3250</b>	14-Mar-2018	Number 8	4-Apr-2024	30-Apr-2025	

## Product designation

**24M, Model SMAPS240VAC, 220~240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

FireBox Australia Pty Ltd  
Lot 5, 19 Balook Drive, BERESFIELD, NSW, AUSTRALIA, 2322

## Conformance criteria and evaluation

The 24M, Model SMAPS240VAC, 220~240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015).

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

## Producer's description

The 24M, Model SMAPS240VAC, 220~240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm is intended for use in domestic and residential dwellings. The 9Vdc battery is user replaceable.

This smoke alarm is interconnectable for up to 12 units.

The smoke alarm operates according to the principle of light scattering. Inside the measuring chamber, which is protected against external light by a black plastic labyrinth, a light emitter and a light receiver are mounted so that no direct light from the emitter can reach the receiver while aerosol is absent in the chamber.

If smoke particles enter the measuring chamber, the light pulse from the light emitter will be scattered by the smoke particles and can thus reach the light receiver. The electronics assess the light incidence and will activate an alarm (both visual and audible) if a predetermined threshold value is exceeded.

This unit is circular in shape and is approximately 140 mm diameter with a height of 43 mm.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kai Loh

Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	Page 2 of 2
<b>afp - 3250</b>	14-Mar-2018	Number 8	Issue date 4-Apr-2024	30-Apr-2025

## Technical specification

The following details are a representative extract of the technical specification for the 24M, Model SMAPS240VAC, 220~240 Vac powered with 9 Vdc battery back-up, hush/silencing facility, interconnectable, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Sensor	Type A, Photoelectric
Power	220~240 Vac 50Hz with 9 Vdc battery backup (replaceable)
Battery replacement	Voltage: 9 Vdc (Carbon Zinc, Alkaline. Lithium battery) Gold Peak: GP1604S (Carbon Zinc Battery) Gold Peak: GP1604A (Alkaline Battery) Raymax: 6LR61 (Alkaline Battery) EVE: CR9V/P (Lithium battery)
Operational current	< 100mA (alarm)
Alarm volume	85 dB(A) at 3 meters
Alarm sensitivity	0.127~0.208 dB/m
Silence time	approx. 8 minutes
Interconnection	Up to 12 units
Smoke alarm device sound pattern:	ISO 8201
Dimensions (approx.)	Diameter 140 mm Height 43 mm

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3048/R2	Evaluation for Conformity of the Siterwell Electronics Co. Limited Model GS517E and GS518E Photoelectric Smoke Alarms to the requirements of AS 3786-2014 +A1:2015	18-May-2017	CSIRO, Fire Systems Laboratory, AU
Document No.	RD-517E-39-001 Version D	Smoke Alarm User Manual Model number: GS517E Ref : ST517E	28-April-2017	Siterwell Electronics Co., Limited, CN