



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3355</b>	13-May-2019	Number 7	Issue date 4-Apr-2024	30-Apr-2025

Page 1 of 3

## Product designation

**Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Guangdong Isafenest Co.,Ltd.  
Room 402, Building 7, Tianfulai II, No. 37 Changbao West Road, Ronggui, Shunde, FOSHAN CITY,  
GUANGDONG, CHINA, 528300

## Registrant

Guangdong Isafenest Co.,Ltd.  
Room 402, Building 7, Tianfulai II, No. 37 Changbao West Road, Ronggui, Shunde, FOSHAN CITY,  
GUANGDONG, CHINA, 528300

### Producer

Guangdong Isafenest Co.,Ltd.  
Room 402, Building 7, Tianfulai II, No. 37 Changbao West Road, Ronggui, Shunde, FOSHAN CITY,  
GUANGDONG, CHINA, 528300

## Conformance criteria and evaluation

The Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015).

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kai Loh

Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3355</b>	13-May-2019	Number 7	Issue date 4-Apr-2024	30-Apr-2025

Page 2 of 3

## Producer's description

The Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm primary power supply is an external 240 Vac supply. The smoke alarm includes a standby power supply from a non-rechargeable battery.

An electric buzzer/horn provides an audible alarm signal when the smoke alarm senses smoke which exceeds a predetermined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energised.

A self test facility is provided by means of a button. If the button is depressed an alarm signal is emitted.

The Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm also incorporates a 'hush button' feature with an independent button for its operation. According to the manufacturer's instructions, pressing the hush button reduces the smoke sensitivity of the smoke alarm. The sensitivity is reduced for approximately 8 minutes, at which time the smoke alarm automatically returns to normal operation.

The Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm is circular in shape and has a different cover to the Isafenest, Model LZ-1907. It is approximately 120 mm diameter with a height of 45 mm. It clips into a circular mounting base with two holes for screws.

## Technical specification

The following details are a representative extract of the technical specification for the Isafenest, Model LZ-1907B, 240 Vac powered with 9 Vdc battery backup, interconnectable, silencing/hush facility, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description
Type	Ident.	
Model num.	LZ-1907B	240 Vac with 9 Vdc battery backup Type A photoelectric smoke alarm with a different cover to LZ-1907.

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Smoke sensing type:	Type A photoelectrical
Main power source:	240 V mains
Standby power:	9V battery (replaceable and not rechargeable)
Battery list:	Energizer 522, Duracell MN 1604 or MX1604, Gold Peak 1604E
Interconnectivity:	Wired (up to 24 devices)
Operating temperature range:	0 °C to 40 °C
Operating humidity range:	0% to 93% RH
Alarm sound level:	85 dB at 3 metres minimum
Alarm condition:	Audible signal pattern (ISO 8201)
Silencing function:	Yes
Dimensions:	Ø120 mm × 45 mm (h)
Fixing method:	Screw fixing
Mounting method:	Wall or ceiling

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 3 of 3
<b>afp - 3355</b>	13-May-2019	Number	Issue date	30-Apr-2025	
		7	4-Apr-2024		

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3229/R2a	Evaluation for Conformity of the Isafenest LZ-1907 Series Photoelectric Smoke Alarm to the requirements of AS 3786:2014 +A1:2015	17-Oct-2023	CSIRO, Fire Systems Laboratory, AU
Doc ref.	1907B Manual.pdf	Installation and User Manual Smoke Alarm Photoelectric Design Model: LZ-1907B (1907B Manual.pdf)	31-Jan-2019	Guangdong Isafenest Co., Ltd, CN