



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 1145</b>	2-Jun-1998	Number 13	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

## Product designation

**Tyco Fire Products, Model EC-11: SIN TY5237, 20NS thread x 16.1K(metric), 57°/68°/79°/93°/141°C (3 mm bulb), extended coverage, pendent, recessed pendent, quick/standard response sprinklers**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Tyco Fire Protection Products  
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

## Registrant

Tyco Fire Protection Products  
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

### Producer

Tyco Fire Protection Products  
8902 North Interstate 27, LUBBOCK, TX, UNITED STATES, 79403

## Conformance criteria and evaluation

The Tyco Fire Products, Model EC-11: SIN TY5237, 20NS thread x 16.1K(metric), 57°/68°/79°/93°/141°C (3 mm bulb), extended coverage, pendent, recessed pendent, quick/standard response sprinklers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories - Evaluation and listing, 'UL listing'.
2. Underwriters Laboratories Canada - Evaluation, follow-up services and listing, 'cUL listing'.
3. Factory Mutual - Evaluation and approval, 'FM approval'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

(Limitations/conditions of conformance continue)

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
<b>afp - 1145</b>	2-Jun-1998	Number 13	Issue date 26-Apr-2019	30-Apr-2020	

- i. Fire sprinkler equipment, system design and installation should be determined and verified in accordance with the performance and prescribed requirements of the regulations, standards and criteria as specified by the building code and authorities having jurisdiction. Due considerations include the occupancy fire loading, sprinkler location, coverage, response, hydraulic characteristics and other specified requirements relevant to the conformance and effectiveness of the equipment and installed system.
- ii. Specific or special requirements in relation to this product must be considered and included in the system design and installation.
- iii. The maximum working pressure is 1210 kPa.

## Producer's description

The Tyco Fire Products, Model EC-11: SIN TY5237, 20NS thread x 16.1K(metric), 57°/68°/79°/93°/141°C (3 mm bulb), extended coverage, pendent, recessed pendent, quick/standard response sprinklers are decorative glass bulb sprinklers designed for use in light or ordinary hazard.

Style 30 or 40 escutcheon components enable appropriate recessed fitment of this device.

## Technical specification

The following details are a representative extract of the technical specification for the Tyco Fire Products, Model EC-11: SIN TY5237, 20NS thread x 16.1K(metric), 57°/68°/79°/93°/141°C (3 mm bulb), extended coverage, pendent, recessed pendent, quick/standard response sprinklers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

SIN	TY5237
Maximum working pressure	1210 kPa (175 psi)
Thread size	20NS (3/4" NPT)
Nominal K-factor	16.1 K(metric), l/min / kPa <sup>0.5</sup> (11.2 GPM/psi <sup>0.5</sup> )
Nominal temperature rating	57°/68°/79°/93°/141°C
Finishes	Natural brass, chrome plated, white polyester, or lead coated
Physical characteristics	
Frame	Bronze
Button	Bronze
Sealing assembly	Beryllium nickel w/Teflon
Bulb	Glass, 3 mm dia.
Compression screw	Bronze
Deflector	Brass
Escutcheon fitment	
Recessed	Style 30 or 40
Flush	Style 60
Reference technical data sheet	TFP220, December 2007