



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1234	27-Apr-1999	Number 15	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Ziton, Model ZP732-2, adjustable nom. sens. (S)=3.0% obs./m, 5.0% obs./m, and 13.0% obs./m, Type A or B at 58° or 75°C, optical/heat analogue sensor detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Kidde Australia
Unit 3, Ground Floor, 10 Ferntree Place, NOTTING HILL, VIC, AUSTRALIA, 3168

Registrant

Kidde Australia
Unit 3, Ground Floor, 10 Ferntree Place, NOTTING HILL, VIC, AUSTRALIA, 3168

Producer

UTC Fire and Security Espana SL
Verge de Guadalupe 3, ESPLUGUES DE LLOBREGAT, BARCELONA, SPAIN, 08950

Conformance criteria and evaluation

The Ziton, Model ZP732-2, adjustable nom. sens. (S)=3.0% obs./m, 5.0% obs./m, and 13.0% obs./m, Type A or B at 58° or 75°C, optical/heat analogue sensor detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.1-1997, 'Automatic fire detection and alarm systems - Heat detectors' incl. Amdt 1 (August 1998).
2. Australian Standard AS 1603.2-1997, 'Automatic fire detection and alarm systems - Point type smoke detectors' incl. Amdt 1 (August 1998).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Connection to the Ziton ZP5-AS2 fire indicator panel (or equivalent) with the detector sensing algorithm version 3.01.
- ii. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



© CSIRO Australia, 2019



This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1234	27-Apr-1999	Number 15	Issue date 26-Apr-2019	30-Apr-2020	

Producer's description

The Ziton, Model ZP732-2/427AA.205, Nominal Sens. (S)=3.0% obs./m, 5.0% obs./m, and 13.0% obs./m, Optical/Thermal Analogue Sensor Detector is an addressable device that continuously measures the analogue ambient smoke and heat levels and reports it to the control unit. Data interpretation and alarm action are undertaken by the control unit. In the alarm state, the built-in LED will flash until reset by the control unit.

Communication and command facilities are built into each detector. Each detector incorporates a 7-way dip switch for address coding.

Technical specification

The following details are a representative extract of the technical specification for the Ziton, Model ZP732-2, adjustable nom. sens. (S)=3.0% obs./m, 5.0% obs./m, and 13.0% obs./m, Type A or B at 58° or 75°C, optical/heat analogue sensor detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Sensitivity:	3% obs./m, 5% obs./m, or 13 % obs./m (set at fire indicator panel)
Nominal operating voltage:	20 V
Voltage range:	15.5 V to 22 V
Quiescent current:	380 µA @ 24 V
Address selector:	7-way dip switch
Temperature range:	-10°C to +75°C
Humidity range:	0 to 95% RH
Dimensions:	106 mm diameter x 58 mm height

Tested base designation	Base + detector circuit type
Ziton, Model ZP7-SB1	Analogue Addressable

Supplementary information

Base assembly connections:

P (+)	Line In/Out (+)
P (-)	Line In/Out (-)
LED (+)	External/Remote LED (+)
LED (-)	External/Remote LED (-)