



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1243	16-Jun-1999	Number 16	Issue date 1-May-2019	30-Apr-2020

Page 1 of 2

Product designation

BFI, HRS Series, fire hose reels

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

BFI Fire Pty Ltd
108A Munibung Rd, BOOLAROO, NSW, AUSTRALIA, 2284

Registrant

BFI Fire Pty Ltd
108A Munibung Rd, BOOLAROO, NSW, AUSTRALIA, 2284

Producer

Steel Recon Industries Sdn Bhd
No. 8, Persiaran Subang (Jalan Subang 7), Taman Perindustrian Subang, SUBANG JAYA, SELANGOR
DARUL EHSAN, MALAYSIA, 47610

Conformance criteria and evaluation

The BFI, HRS Series, fire hose reels have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1221:1997, 'Fire hose reels' incl. Amdt 1 (23 January 2003).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1243	16-Jun-1999	Number 16	Issue date 1-May-2019	30-Apr-2020	

Producer's description

The BFI, HRS Series, fire hose reels are designed for one-person operation and allow immediate and continuous flow of water at all times during deployment of the hose.

Technical specification

The following details are a representative extract of the technical specification for the BFI, HRS Series, fire hose reels and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Trade brand	Model	Hose	
		Length	Diameter
BFI	HRS035-GI-019-RD	36 m	19 mm
BFI	HRS037-GI-019-RD	30m or 36 m	19 mm

Schedule of properties/characteristics

Drum:	Mild Steel (Finish: red polyester)
Water way:	Aluminium alloy BS 1490 LM 16 or LM 24 Red
Inlet pipe:	Galvanised mild steel
Outlet diameter:	20mm
Hose length:	36m, HRS035-GI-019-RD 30m or 36m, HRS037-GI-019-RD
Working pressure:	1 MPa
Test pressure:	1.7 Mpa

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Certificate No.	SMK1355	StandardsMark Licence Steel Recon Industries SDN BHD Manufactured to: AS/NZS 1221:1997 - Fire hose reels (SF01.AS121854.SMK1355.4.pdf)	10-Jul-2018	SAI Global Certification Services Pty Ltd, AU