



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1329	15-May-2000	Number 14	Issue date 27-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Tyco, Model SU0601, manual call point

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Tyco Fire Protection Products
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

Registrant

Johnson Controls
17 Mary Muller Drive, HILLSBOROUGH, CHRISTCHURCH, NEW ZEALAND, 8022

Producer

KAC Alarm Company Limited
KAC House, Thornhill Road, North Moons Moat, REDDITCH, WORCESTERSHIRE, UNITED KINGDOM, B98 9ND

Conformance criteria and evaluation

The Tyco, Model SU0601, manual call point has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.5-1996, 'Automatic fire detection and alarm systems - Manual call points (all requirements other than weathering)' incl. Amdt 1 (August 1998).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Suitable for an indoor and dry environment.
- ii. Compatibility of this device with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1329	15-May-2000	Number 14	Issue date 27-Apr-2019	30-Apr-2020	

Producer's description

The Tyco, Model SU0601, manual call point is a red, indoor, surface mounted, break glass manual call point with normally open, closing on contact alarm contacts.

The MCP can be converted to a resettable model by substituting the glass element with a resettable frangible element.

The red plastic mounting box has a tear-off template for locating cable entry holes.

Technical specification

The following details are a representative extract of the technical specification for the Tyco, Model SU0601, manual call point and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Maximum working voltage:	30 Vdc 50 Vac 45/60 Hz
Maximum current rating:	3A
Material:	Polycarbonate ABS blend Self-extinguishing V-0 to UL 94
Dimensions:	87w x 87h x 52d (on a surface mount box)

Supplementary information