



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 1335</b>	18-May-2000	Number 14	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

## Product designation

**Chubb Fire Safety Limited, 3000 Series, carbon dioxide type portable fire extinguishers**  
(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Chubb Fire & Security Pty Ltd  
314 Boundary Road, DINGLEY, VIC, AUSTRALIA, 3172

## Registrant

Chubb Fire & Security Pty Ltd  
314 Boundary Road, DINGLEY, VIC, AUSTRALIA, 3172

## Producer

## Conformance criteria and evaluation

The Chubb Fire Safety Limited, 3000 Series, carbon dioxide type portable fire extinguishers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.6:1997, 'Portable fire extinguishers - Specific requirements for carbon dioxide type extinguishers'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 1335</b>	18-May-2000	Number 14	Issue date 26-Apr-2019	30-Apr-2020

Page 2 of 2

## Technical specification

The following details are a representative extract of the technical specification for the Chubb Fire Safety Limited, 3000 Series, carbon dioxide type portable fire extinguishers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Model	Capacity (Nominal)	Brand	FERN	Extinguishant	Rating
3006/01	2.0 kg	Chubb	25565-LF-7106	Carbon Dioxide	2B:E
3007/17	2.0 kg	Flameguard R	25565-DA-7109	Carbon Dioxide	2B:E
3001/01	3.5 kg	Chubb	25565-LF-7110	Carbon Dioxide	5B:E
3008/17	3.5 kg	Flameguard R	25565-DA-7110	Carbon Dioxide	5B:E
3002/01	5.0 kg	Chubb	25565-LF-7111	Carbon Dioxide	10B:E
3009/17	5.0 kg	Flameguard R	25565-DA-7111	Carbon Dioxide	10B:E

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Certificate No.	SMKH25565	StandardsMark Licence Manufactured to AS/NZS 1841.6:1997, 'Portable fire extinguishers - Specific requirements for carbon dioxide type extinguishers'	14 Nov 2012	SAI Global, AU