



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1388	27-Feb-2001	Number 16	Issue date 1-May-2019	30-Apr-2020

Page 1 of 2

Product designation

Ademco, Model 1600EC, nom. sens. (S)=0.40 MIC X, ionisation smoke detector
(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Honeywell Security and Fire
9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

Honeywell Security and Fire
9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Producer

System Sensor Europe
3 Horsham Gates, North Street, HORSHAM, WEST SUSSEX, UNITED KINGDOM, RH13 5PJ

Conformance criteria and evaluation

The Ademco, Model 1600EC, nom. sens. (S)=0.40 MIC X, ionisation smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.2-1997, 'Automatic fire detection and alarm systems - Point type smoke detectors' incl. Amdt 1 (August 1998).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 1388	27-Feb-2001	Number 16	Issue date 1-May-2019	30-Apr-2020	

Producer's description

The Ademco, Model 1600EC, nom. sens. (S)=0.40 MIC X, ionisation smoke detector uses an ionisation chamber containing a radioactive source, Americium AM241, for sensing smoke. The detector is designed to provide open area protection and to be used with a compatible control and indicating fire panel.

Two LEDs on each detector provide a local 360° visible alarm indication. In quiescent state the LEDs flash every ten (10) seconds indicating power is applied and the detector is operating. In alarm the detector has a latching feature causing the LEDs to illuminate continuously. The detector is reset from alarm state into the sense state by a momentary power interruption.

Activating an internal reed switch with a magnet may test the detector.

Technical specification

The following details are a representative extract of the technical specification for the Ademco, Model 1600EC, nom. sens. (S)=0.40 MIC X, ionisation smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Voltage range:	8.5 Vdc to 35 Vdc
Standby current:	120 µA maximum
Alarm state voltages:	4.2 Vdc @ 10 mA 6.6 Vdc @ 100 mA
Operating temperature range:	-10° to 60°C
Operating humidity range:	10% to 93% relative humidity non-condensing

Tested base designation	Base + detector circuit type
System Sensor, Model B401	Conventional