



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2381	25-Nov-2009	Number 11	Issue date 1-May-2018	30-Apr-2019

Page 1 of 2

Product designation

Notifier, Model FSC-851AUS, multi criteria fire sensor

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Notifier Inertia

9 Columbia Way, Norwest Business Park, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

System Sensor Europe

Javastrasse 2, Unit C2, Foundry Lane, HEGNAU, SWITZERLAND, CH-8604

Producer

System Sensor Europe

Javastrasse 2, Unit C2, Foundry Lane, HEGNAU, SWITZERLAND, CH-8604

Conformance criteria and evaluation

The Notifier, Model FSC-851AUS, multi criteria fire sensor has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.5-2004, 'Fire detection and alarm systems - Part 5: Point type heat detectors (ISO 7240-5:2003, MOD)'.
2. Australian Standard AS 7240.7-2004, 'Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Installation and fitment of the detector using the Model B501 base.
- ii. The mode settings for advanced application are not used.
- iii. Installation of the detector is used in indoor dry environments,
- iv. Installation and maintenance as recommended by the supplier/manufacturer.
- v. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

Issued by

David Whittaker

Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2381	25-Nov-2009	Number 11	Issue date 1-May-2018	30-Apr-2019	

Producer's description

The Notifier, Model FSC-851AUS, multi criteria fire sensor is a microprocessor controlled, analogue addressable multi-sensor.

This fire detector incorporates four separate sensing elements. A carbon monoxide sensor (using an electrochemical cell), an infra red photo diode, a photoelectric smoke sensing chamber using the optical scatter principle and thermal detection using a thermistor.

The detector has six sensitivity settings which can be selected at the associated control and indicating equipment. Five sensitivity settings from least smoke sensitive to most smoke sensitive, each including heat operation, and one heat only setting in which the smoke sensing element is disabled.

The detector is a plug in sensor compatible with the Notifier, Model B501 detector base. Two LEDs on the sensor pulse as the detector is polled by the associated control and indicating equipment. These LEDs illuminate red to indicate the alarm status of the device.

The loop address of the device is set in the range from device 1 to device 159 using two rotary decade address switches on the rear of the detector.

The physical dimensions are 102 mm diameter and 60 mm high without base.

Technical specification

The following details are a representative extract of the technical specification for the Notifier, Model FSC-851AUS, multi criteria fire sensor and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage range:	15 to 32 Vdc
Maximum average standby current:	300 μ A (with LED blink enabled)
Alarm current:	7 mA @ 24 Vdc
Nominal activation temperature:	60 °C
Operating temperature range:	-20 to 55 °C
Operating humidity range:	15 to 90 % RH, non-condensing
Construction:	102mm dia x 80mm high. 110g (with B501 base)

Tested base designation	Base + detector circuit type
Notifier, Model B501	Analogue Addressable