



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2396	10-Feb-2010	Number 11	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Flamestop, FSAW Series, water type fire extinguisher

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

FlameStop Australia Pty. Ltd.
1/70 Gibbes St, CHATSWOOD, NSW, AUSTRALIA, 2067

Registrant

FlameStop Australia Pty. Ltd.
1/70 Gibbes St, CHATSWOOD, NSW, AUSTRALIA, 2067

Producer

FlameStop Australia Pty. Ltd.
1/70 Gibbes St, CHATSWOOD, NSW, AUSTRALIA, 2067

Conformance criteria and evaluation

The Flamestop, FSAW Series, water type fire extinguisher has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.2:2007, 'Portable fire extinguishers - Specific requirements for water type extinguishers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Water type fire extinguishers are suitable for use on Class A fires; not suitable for classes 'B', 'E' or 'F' where flammable and combustible liquids, electrically energised equipment and cooking oil and fats are involved.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2396	10-Feb-2010	Number	Issue date	30-Apr-2020	
		11	26-Apr-2019		

Producer's description

Recommended for Class 'A' fires, the Flamestop, FSAW Series, water type fire extinguisher is available only in the most common 9 litre capacity.

Acting to reduce the temperature of the burning fuel, the Air/Water extinguisher is used to disperse fires involving wood, paper, plastics, textiles, rubber and rubbish. Once the burning fuel has been reduced to below the ignition temperature, the fire can be brought under control. It is important to remember that this type of extinguisher is NOT suitable for classes 'B', 'E' or 'F' where flammable and combustible liquids, electrically energised equipment and cooking oil and fats are involved.

Technical specification

The following details are a representative extract of the technical specification for the Flamestop, FSAW Series, water type fire extinguisher and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Model num.	Capacity (Nominal)	Brand	Reference num.	Rating
FS AW 900	9.0 l	Flamestop	20421-LM-2401	3A

Model num.:	FS AW 900
Part num.:	G9LAW
Agent type:	Air and water
Total mass:	12.1 kg
Working pressure:	700 kPa
Periodic test pressure:	2.5 MPa
Dimensions	
Height:	660 mm
Width:	175 mm
Construction	
Cylinder:	Stainless steel
Valve:	Brass
Finish	
Cylinder:	Powder coated red
Valve:	Nickel plated brass
Handles:	Stainless steel

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Certificate No.	SMKH20421	StandardsMark Licence Manufactured to AS/NZS 1841.2:2007, 'Portable fire extinguishers - Specific requirements for water type extinguishers'	28 May 2012	SAI Global, AU