



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2416	24-Mar-2010	Number 10	Issue date 1-May-2019	30-Apr-2020

Page 1 of 2

Product designation

Siemens, Model DM1151, manual call point

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Siemens Ltd.
885 Mountain Highway, BAYSWATER, VIC, AUSTRALIA, 3153

Registrant

Siemens Ltd.
885 Mountain Highway, BAYSWATER, VIC, AUSTRALIA, 3153

Producer

Siemens Switzerland Ltd
Theilerstrasse 1a, ZUG, SWITZERLAND, CH-6300

Conformance criteria and evaluation

The Siemens, Model DM1151, manual call point has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. European Standard EN 54-11(Type A):2001, 'Fire detection and fire alarm systems. Manual call points'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2416	24-Mar-2010	Number 10	Issue date 1-May-2019	30-Apr-2020	

Producer's description

The Siemens, Model DM1151, manual call point is an individually addressed component of the Siemens Interactive series fire detection products. It is a Type A, loop powered, manual call point which is specified for surface or recessed mounting. It is designed for both indoor and outdoor use.

It is designed to be used in conjunction with a system controller (c.i.e.) to manually initiate a fire alarm by breakage of a replaceable glass frangible element. The device incorporates a response indicated (red LED) build into the operating face of the unit. An alarm signal is sent to the loop controller when the frangible element is displaced releasing a push button. Replacement of the frangible element returns the push button into position and the device is returned to its quiescent state.

Technical specification

The following details are a representative extract of the technical specification for the Siemens, Model DM1151, manual call point and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage (modulated):	21.2 to 33.3 Vdc
Terminal block:	0.28 – 1.5 mm ²
Operating temperature:	-25° to 70°C
Humidity (non-condensing):	≤ 95 %RH
Color:	Red, ~RA 3000 Blue, ~RAL 5005 Yellow, ~RAL 1023 Green, ~RAL 6024
Protection category:	IP44