



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2420	4-May-2010	Number 12	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

InnovairFlex™, Model D2-AUS, duct sampling unit

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Honeywell Security Group
Unit 5, Riverside Centre, 24-28 River Road West, PARRAMATTA, NSW, AUSTRALIA, 2150

Registrant

System Sensor, Ltd
3825 Ohio Avenue, ST CHARLES, IL, UNITED STATES, 60174

Producer

System Sensor, Ltd
3825 Ohio Avenue, ST CHARLES, IL, UNITED STATES, 60174

Conformance criteria and evaluation

The InnovairFlex™, Model D2-AUS, duct sampling unit has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.13-1998, 'Automatic fire detection and alarm systems - Duct sampling units'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. the unit is used in conjunction with the one of the following smoke detectors.
 - a. System Sensor, Model 2151BAUS, or
 - b. System Sensor, Model 2151BPI, or
 - c. Honeywell, Model 2600M.
- ii. Compatibility of the fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.
- iii. the extended air-speed operating ranges of the unit of less than 1 m/s and greater than 8 m/s were have not been verified.
- iv. operation of the unit at temperatures below -10°C has not been verified.
- v. the unit is used in indoor dry environments.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



© CSIRO Australia, 2019



This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2420	4-May-2010	Number 12	Issue date 26-Apr-2019	30-Apr-2020	

(Limitations/conditions of conformance continue)

- vi. the unit is installed and maintained as recommended by the manufacturer.
- vii. the unit is not used with the remote test coil accessory described in the Installation Instructions.
- viii. the unit is supplied with labels in accordance with the conformance criteria.

Producer's description

The InnovairFlex™, Model D2-AUS, duct sampling unit includes a housing for plug-in type smoke detectors for detection of smoke in air-handling ducts.

The combination of housing and detector provided by the Model D2-AUS utilizes photoelectric technology for the detection of smoke. When sufficient smoke is sensed, an alarm signal is initiated at the compatible control and indicating equipment (CIE).

The Model D2-AUS unit consists of the following components:

- InnovairFlex Model D2-AUS DSU housing and cover, sampling tube and exhaust tube, and
- System Sensor 2151BAUS or 2151BPI, or Honeywell 2600M, conventional photoelectric smoke detector and compatible base.

The alarm state of the Model D2-AUS is indicated by the illumination of a LED fitted to the detector.

Technical specification

The following details are a representative extract of the technical specification for the InnovairFlex™, Model D2-AUS, duct sampling unit and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Evaluated components

Product assembly designation		
InnovairFlex™, Model D2-AUS, duct sampling unit		
Detector (photoelectric) component designation	Base designation	Base + detector circuit type
System Sensor, Model 2151BAUS	System Sensor, Model B401	Conventional
System Sensor, Model 2151BPI		
Honeywell, Model 2600M		

Nominal sensitivity:	4.0 %obs/m
Operating voltages:	8.5 – 35 Vdc
Quiescent current/voltage:	60 mA (average), 120 mA (peak)
Alarm current:	130 mA
Operating temperature range:	-10 to 70°C
Humidity range:	0 to 93 %RH