



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2433	17-Aug-2010	Number 10	Issue date 12-Apr-2019	30-Apr-2020

Page 1 of 4

Product designation

Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system
(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Pyrogen Technologies (Aust) Pty Ltd
18 Barry Avenue, MORTDALE, NSW, AUSTRALIA, 2223

Registrant

Pyrogen Technologies (Aust) Pty Ltd
18 Barry Avenue, MORTDALE, NSW, AUSTRALIA, 2223

Producer

Pyrogen Technologies (Aust) Pty Ltd
18 Barry Avenue, MORTDALE, NSW, AUSTRALIA, 2223

Conformance criteria and evaluation

The Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1851.16:1997, 'Maintenance of fire protection equipment - Pyrogen fire extinguishing aerosol systems'.
2. Australian/New Zealand Standard AS/NZS 4487:1997, 'Pyrogen fire extinguishing aerosol systems'.
3. NFPA Standard NFPA 2010-2006, 'Aerosol Fire Extinguishing Systems'.
4. CEN/TR 15276-1:2009, 'Fixed firefighting systems - Condensed aerosol extinguishing systems - Part 1: Requirements and test methods for components'.
5. CEN/TR 15276-2:2009, 'Fixed firefighting systems - Condensed aerosol extinguishing systems - Part 2: Design, installation and maintenance'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

(Limitations/conditions of conformance continue)

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



© CSIRO Australia, 2019



This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 2433	17-Aug-2010	Number 10	Issue date 12-Apr-2019	30-Apr-2020	Page 2 of 4

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. This equipment is intended for use in normally unoccupied areas. Use in protected areas, which may be occupied, is subject to effective design strategies, requirements and measures for human evacuation which are determined and verified in accordance with the relevant requirements of the regulations, standards and criteria as accepted authorities having jurisdiction.
- ii. Ambient temperature of protected enclosure between -50°C and +65°C. (WIN models) and -50°C and +85°C (WIN-M models).
- iii. Design and installation shall be done in accordance with the Pyrogen[®], Design, Operation & Maintenance Manual, Fixed Aerosol Fire Suppression System, Revision No. 2.0, Issued July 2008 (Pyrogen[®] Part No. D2005-0205)
- iv. Height limitations height to protected enclosure in accordance with following table.

General Series		M Series	
Generator	Max. enclosure height	Generator	Max. enclosure height
WIN-Z3	1 m	WIN-M-Z2	1 m
WIN-Z6	1.25 m	WIN-M-Z6	1.25 m
WIN-1	2.0 m	WIN-ML-1	2.0 m
WIN-2	2.5 m	WIN-MS-1	2.0 m
WIN-5	3.0 m	WIN-M-2	2.5 m
WIN-10	3.5 m	WIN-M-5	3.0 m
WIN-20	4.0 m	WIN-M-10	3.5 m
WIN-30	4.0 m	WIN-MB-10	3.5 m
WIN-50	4.5 m		

- v. Due to a potential hazard of high temperatures at the end-plate nozzle, the following minimum clearances from the discharge nozzle for each type of generator should be observed during installation

General Series		M Series	
Generator	Minimum clearance	Generator	Minimum clearance
WIN-Z3	200 mm	WIN-M-Z2	150 mm
WIN-Z6	300 mm	WIN-M-Z6	300 mm
WIN-1	400 mm	WIN-ML-1	400 mm
WIN-2	700 mm	WIN-MS-1	400 mm
WIN-5	700 mm	WIN-M-2	700 mm
WIN-10	1000 mm	WIN-M-5	700 mm
WIN-20 to WIN-50	1,500 to 2,000 mm	WIN-M-10	1,000 mm
		WIN-MB-10 (at each end)	700 mm

Producer's description

The Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system is a pre engineered compact, non-stored pressure, electrically-actuated fixed fire protection system which extinguishes fire by using an extremely fine low settling-rate chemical dry-powder plus inert gases. The powder particles are induced into the fire and quickly cause complete chemical inhibition of the fire's radical-forming chain reactions. This, together with the oxygen dilution and cooling produced by the inert gases, rapidly extinguishes the flaming combustion of most fuels. The chemical dry-powder and inert gases are produced by a rapid but non-explosive exothermic reaction, of a patented "aerosol-forming substance", which commences within the shell of each Pyrogen[®] "generator" immediately after electric initiation. During the reaction, the inert gases and "micron-sized" particles of powdered chemical extinguishant are forcefully ejected from the nozzle holes of the generator and thereby thoroughly mixed with the atmosphere within the protected area. The inert gases emitted by the generator are predominantly nitrogen, carbon dioxide, and water vapour. At a specified minimum clearance from a nozzle opening the aerosol temperature shall not exceed 200°C (CEN, ISO) when in contact with combustible materials and 400°C (CEN, ISO) when in contact with non-combustible materials.

The initiation of the WIN/WIN-M Series generators is by means of an electrical activation ignition device located inside the generator. Any extinguishing system control panel is likely to be capable of activating one or several generators simultaneously. A suitable panel should be chosen by reference to the Pyrogen[®] Fixed Aerosol – Fire Suppression System Manual, or with the help of an authorised Pyrogen[®] equipment supplier.

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2433	17-Aug-2010	Number 10	Issue date 12-Apr-2019	30-Apr-2020
				Page 3 of 4

The supplied equipment of a Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system includes, mounting brackets, and all necessary fasteners to attach these to the generator. A weather and vibration resistant electrical connector with a plug or a junction box with electrical terminals is furnished with all generators.

The Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system is suitable for use in marine or tropical environments, as evidenced by results of its testing for resistance to vibration, salt-spray corrosion, and moisture ingress. Accidental and deliberate releases of Pyrogen® aerosol do not contribute to global atmospheric warming or ozone depletion.

Technical specification

The following details are a representative extract of the technical specification for the Pascal, WIN/WIN-M Series, pyrotechnically generated, aerosol fixed fire suppression system and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Generator	Mass of generator	Mass of aerosol forming composition	Max. protected volume @ 100 g/m ³	Nozzle outlet	Length	Diameter	Discharge times
WIN-Z3	360 g	30 g	0.3 m ³	Mono	101 mm	38 mm	20 s
WIN-Z6	650 g	60 g	0.6 m ³	Mono	121 mm	51 mm	25 s
WIN-1	940 g	100 g	1 m ³	Mono	122 mm	64 mm	30 s
WIN-2	1,700 g	200 g	2 m ³	Mono	200 mm	76.2 mm	30 s
WIN-5	2,850 g	500 g	5 m ³	Mono	215 mm	89 mm	30 s
WIN-10	10,000 g	1,000 g	10 m ³	Mono/Radial	200 mm	220 mm	30 s
WIN-20	17,500 g	2,000 g	20 m ³	Mono	254 mm	220 mm	30 s
WIN-30	25,500 g	3,000 g	30 m ³	Mono	342 mm	310 mm	35 s
WIN-50	30,000 g	5,000 g	50 m ³	Mono	450 mm	310 mm	35 s
WIN-M-Z2	300 g	20 g	0.2 m ³	Mono	80 mm	40 mm	5 s
WIN-M-Z6	650 g	60 g	0.6 m ³	Mono	160 mm	40 mm	10 s
WIN-ML-1	800 g	100 g	1 m ³	Mono	240 mm	40 mm	15 s
WIN-MS-1	800 g	100 g	1 m ³	Mono	105 mm	70 mm	15 s
WIN-M-2	1,200 g	200 g	2 m ³	Mono	162 mm	70 mm	15 s
WIN-M-5	2,300 g	500 g	5 m ³	Mono	242 mm	113 mm	15 s
WIN-M-10	8,500 g	1,000 g	10 m ³	Mono	434 mm	113 mm	20 s
WIN-MB-10	8,500 g	1,000 g	10 m ³	Bi	434 mm	113 mm	20 s

Accessories	Part number
Thermal activation device T-start-45C	302 T-45
Thermal activation device T-start-72C	303 T-72
Thermal activation device T-start-110C	304 T-110
Activation device T-start Manual	305 T-man
Detection circuit junction box for T-start/ TAD	306 DCJB
Protective cup	307 P CUP
High lithium power accelerator for T-start/ TAD with isolation switch	308 HL-PAWIS
Solid electrolyte power accelerator for T-start/ TAD with isolation switch	309 SEP-PAWIS
Back up rechargeable power accelerator For T-start/ TAD with isolation switch	310 BUR-PAWIS
Thermal activation device TAD-45	TAD-45
Thermal activation device TAD-72	TAD-72
Thermal activation device TAD-110	TAD-110
Thermal activation device TAD-P (manual operation)	TAD-P
Activation device TAD-manual	TAD_Manual, Rev. 1.3
FireChase Detection and Actuation System With Isolation Switch	101 2ZWDIS
FireChase Detection and Actuation System	102 2ZD
FireChase Detection system two circuit	103 2ZIP
FireChase Detection system four circuit	104 4ZIP
FireChase CNC Detection and Actuation System	107 CNC FDDP
Dual-Output Booster (fully monitored) to increase number of connected canisters or use high current output for ancillaries up to 5Amp	201 DOB2
Junction Box for Monitoring 1 Discharge Line (metal case for industrial panel)	202 JB-1IN
Junction Box for Monitoring 2(3) Discharge Lines (plastic case for	203 JB-2/3 MA

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2433	17-Aug-2010	Number 10	Issue date 12-Apr-2019	30-Apr-2020
				Page 4 of 4

Accessories	Part number
marine & automotive applications)	
Junction Box for Monitoring 4(5) Discharge Lines (plastic case for marine & automotive applications)	204 JB-4/5 MA
Flush-mounting Plate for Detection and Activation System	205 FMP CP 101-4
Igniter Interface Unit (IIU) to monitor Discharge line through SFM (1 IIU per canister)	206 IIU
Supervision Firing Module (SFM) - universal interface to monitor & discharge (up to 10) canisters by any type of Detection and Activation Systems	207 SFM
Junction Box for Monitoring 2(3) Discharge Lines (aluminum casting case suitable for aggressive environment in marine & automotive applications)	208 ALJB-2/3 MA
Junction Box for Monitoring 4(5) Discharge Lines (aluminum casting case suitable for aggressive environment in marine & automotive applications)	209 ALJB-4/5 MA
Power pack input 240 VAC output 12 VDC 7.2A/h Battery in a box	701 PP12
Power pack input 240 VAC output 24 VDC 7.2A/h Battery in a box	702 PP24
12VDC 7.2A/h Back up battery in a box with isolation switch for vehicle and marine applications	703 BUB12
24VDC 7.2A/h Back up battery in a box with isolation switch for vehicle and marine applications	704 BUB24
Sign Illuminated with Sounder EVAC	513SIWS-EVAC
Sign Illuminated with Sounder DNE	514IWS-DNE

Classifications:

Suitable for fire

Class A – combustible solids
Class B – flammable liquids
Class C – flammable gases
Class E – electrically energised fires

Handling and transport:

In accordance with the requirements for goods classification as U.N. No. 3178
Dangerous Goods Class 4.1, Category C, Hazchem Code 1[T]

Minimum design factor:

Class B and surface Class A fires:

100 g/m³

Dense cable fires:

200 g/m³

Canister characteristics:

Material:

Stainless steel (WIN models)
Stainless or galvanised mild steel (WIN-M models)

Temperature range:

-50° to +65°C (WIN models); -50° to +85°C (WIN-M models)

Humidity range of application:

0 - 98%, non-condensing

Shock:

Tested at 10g for >13,000 impacts

Vibration:

5g @ 50 - 250Hz

Corrosion resistance:

Exceeds UL 1058 requirements

Aerosol characteristics:

Minimum particle size:

1 micron

Oxygen level:

17% to 20% (typical)

Electrical activation:

Nominal resistance:

0.6 - 5.0 Ohms (depends on model)

Activation current:

100 - 1500 mA (depends on model)

Actuation time:

2 -10 milliseconds

Service life:

5 - 10 years