



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2445	17-Sep-2010	Number 10	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Ziton, Model ZP785-3, manual call point

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Kidde Australia
Unit 3, Ground Floor, 10 Ferntree Place, NOTTING HILL, VIC, AUSTRALIA, 3168

Registrant

Kidde Australia
Unit 3, Ground Floor, 10 Ferntree Place, NOTTING HILL, VIC, AUSTRALIA, 3168

Producer

UTC Fire and Security Espana SL
Verge de Guadalupe 3, ESPLUGUES DE LLOBREGAT, BARCELONA, SPAIN, 08950

Conformance criteria and evaluation

The Ziton, Model ZP785-3, manual call point has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. European Standard EN 54-11(Type A):2001, 'Fire detection and fire alarm systems. Manual call points'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. This product is to be installed in a dry, indoor, environment.
- ii. Compatibility of this device with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2445	17-Sep-2010	Number 10	Issue date 26-Apr-2019	30-Apr-2020	

Producer's description

The Ziton, Model ZP785-3, manual call point is a component of the Ziton series products. It is a type A, loop powered, analogue addressable manual call point which is specified for surface or recessed mounting. It is designed for indoor use only.

It is designed to be used in conjunction with a system controller (c.i.e.) to manually initiate a fire alarm by breakage of a replaceable glass frangible element. One device address is required, which is configured by a series of binary DIP switches mounted to the rear of the product. An alarm signal is sent to the loop controller when the switch is closed (ie. when the glass is broken).

Technical specification

The following details are a representative extract of the technical specification for the Ziton, Model ZP785-3, manual call point and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage:	19.5 to 20.5 V (pulsed)
Standby current:	400 mA
Activated current:	450 mA
Operating temperature range:	10 to 50 C
Operating humidity range:	20 to 95% RH
Mounting:	Surface
Construction:	Moulded ABS
Wiring:	ZP loop - 2 core plus screen
Dimensions:	89 x 93 x 27.5 mm