



Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|----------|------------------------|-------------|
| afp - 2498 | 30-May-2011 | Number 8 | Issue date 24-Apr-2019 | 30-Apr-2020 |

Page 1 of 1

Product designation

Victaulic, Series V34: SIN V3402, 20NS NPT thread x 11.5K(metric), 57°/68°/79°/93°/141°C, spr. upr. (SSU), quick response sprinklers

Agent/distributor

Victaulic Australia Pty Ltd
Unit 1, 7 Chambers Road, ALTONA NORTH, VIC, AUSTRALIA, 3025

Registrant

Victaulic® Company
4901 Kesslersville, EASTON, PA, UNITED STATES, 18044-0031

Producer

Victaulic® Company
4901 Kesslersville, EASTON, PA, UNITED STATES, 18044-0031

Conformance criteria and evaluation

The Victaulic, Series V34: SIN V3402, 20NS NPT thread x 11.5K(metric), 57°/68°/79°/93°/141°C, spr. upr. (SSU), quick response sprinklers has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Factory Mutual - Evaluation and approval, 'FM approval'.
2. Approval Standard FM Class Number 2000:March 2006, 'Approval Standard for Automatic Control Mode Sprinklers for Fire Protection'.
3. Underwriters Laboratories - Evaluation and listing, 'UL listing'.
4. Underwriters Laboratories Standard UL 199, Edition 11, 'Automatic Fire Sprinklers for Fire Protection Service'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme

