



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 2519	12-Aug-2011	Number 9	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Notifier, Model CPX-851AUS, nom. sens. (S)=0.4 MIC X, ionisation smoke detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Honeywell Security and Fire
9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

Xi'an System Sensor Electronics, Ltd
28 Tuan Jie South Road, Xi'an Hi-tech Development Zone, XI'AN, SHAANXI, CHINA, 710075

Producer

Xi'an System Sensor Electronics, Ltd
11 Xiao Zhai East Road, XIAN, SHAANXI, CHINA, 710061

Conformance criteria and evaluation

The Notifier, Model CPX-851AUS, nom. sens. (S)=0.4 MIC X, ionisation smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.2-1997, 'Automatic fire detection and alarm systems - Point type smoke detectors' incl. Amdt 1 (August 1998).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Evaluation of this device was subject to connection to the Notifier Inertia, Model AFP-2800, fire indicator panel (software version v5.05B4).
- ii. This device is suitable for use in indoor dry environments.
- iii. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 2519	12-Aug-2011	Number 9	Issue date 26-Apr-2019	30-Apr-2020	

Producer's description

The Notifier, Model CPX-851AUS, nom. sens. (S)=0.4 MIC X, ionisation smoke detector is a re-settable, analogue addressable device. The detector is intended for use with compatible control and indicating equipment (c.i.e.) with connection via a suitable base.

Two indicating LEDs on each detector light to provide a local, visible detector indication. The detector may be tested in-situ using either a test magnet to activate the test feature or an aerosol generator applied until the c.i.e. enters the alarm state. Once activated, the detector must be reset at the c.i.e.

This device supports both FlashScan® and CLIP (Classic Loop Interface Protocol)

Technical specification

The following details are a representative extract of the technical specification for the Notifier, Model CPX-851AUS, nom. sens. (S)=0.4 MIC X, ionisation smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage range:	15 to 32 Vdc
Quiescent current:	300 µA @ 24 Vdc
Alarm current:	6.5 mA @ 24 Vdc
Sensitivity (S):	0.4 MIC X
Source material:	0.5 microcurie, Americium 241
Operating temperature range:	0°C to +49°C
Communication protocol	FlashScan® or CLIP (Classic Loop Interface Protocol).
Height:	43 mm (installed on B501 base assembly)
Diameter:	104 mm

Tested base designation	Base + detector circuit type
System Sensor, Model B501	Analogue Addressable