



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3424</b>	1-Feb-2020	Number 0	Issue date 1-Feb-2020	30-Apr-2021

Page 1 of 2

## Product designation

**VESDA®, VESDA-E VES series, aspirating smoke detector**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Xtralis Pty Ltd  
4 North Drive, Virginia Park, 236-262 East Boundary Road, BENTLEIGH EAST, VIC, AUSTRALIA, 3165

## Registrant

Xtralis Pty Ltd  
4 North Drive, Virginia Park, 236-262 East Boundary Road, BENTLEIGH EAST, VIC, AUSTRALIA, 3165

### Producer

Xtralis Pty Ltd  
4 North Drive, Virginia Park, 236-262 East Boundary Road, BENTLEIGH EAST, VIC, AUSTRALIA, 3165

## Conformance criteria and evaluation

The VESDA®, VESDA-E VES series, aspirating smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.20-2012, 'Fire detection and alarm systems - Part 20: Aspirating smoke detectors'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



Registration Certificate : Validation Issue

© CSIRO Australia, 2020



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
<b>afp - 3424</b>	1-Feb-2020	Number 0	Issue date 1-Feb-2020	30-Apr-2021	

## Technical specification

The following details are a representative extract of the technical specification for the VESDA®, VESDA-E VES series, aspirating smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description
Type	Ident.	
Model	VES-A00-P	aspirating smoke detector with LED display
	VES-A10-P	aspirating smoke detector with LED display and 3.5" colour touch screen

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report Number	XF3345/R1	Evaluation for conformity of the VESDA-E VES series, aspirating smoke detector to the requirements of AS 7240.20-2012	1-Feb-2020	CSIRO, Fire Systems Laboratory, AU