



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 373	30-Aug-1989	Number 12	Issue date 1-May-2018	30-Apr-2019

Page 1 of 2

Product designation

Thorn, Model S121, solar blind infra-red flame detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Tyco Fire Protection Products
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

Registrant

Johnson Controls
17 Mary Muller Drive, HILLSBOROUGH, CHRISTCHURCH, NEW ZEALAND, 8022

Producer

Thorn Security Limited
Security House, The Summit, Hanworth Road, SUNBURY-ON-THAMES, MIDDLESEX, UNITED KINGDOM,
TW16 5DB

Conformance criteria and evaluation

The Thorn, Model S121, solar blind infra-red flame detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. SSL Major Report No. 184:June-1977, 'Comparative Performance of Flame Detectors'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 373	30-Aug-1989	Number 12	Issue date 1-May-2018	30-Apr-2019	

Producer's description

The Thorn, Model S121, solar blind infra-red flame detector is designed to provide early warning of flaming fires involving carbonaceous materials, The S121 detector uses infra-red sensors and filters in the rejection of deceptive phenomena while retaining the inherent advantages of infra-red detectors. The S121 detector uses optical filters to restrict the response to a narrow band in the region of 4.4µm.

The Thorn, Model S121, solar blind infra-red flame detector by virtue of its construction and rejection of spurious radiation, may be used in almost any application either indoors or outdoors.

Technical specification

The following details are a representative extract of the technical specification for the Thorn, Model S121, solar blind infra-red flame detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Supply voltage:	16 to 23 Vdc (polarity conscious)
Quiescent current:	100 µA maximum @ 20 Vdc
Alarm output mode:	2-wire, latching 330Ω in series with 3 V switched across supply.
Alarm current:	60 mA maximum
Alarm indication:	Red LED visible from front of door
Reset time:	3 seconds, typical 5 seconds, maximum
Reset voltage:	Supply must be reduced to less than 2 V
Stabilisation time:	20 seconds, typical
Operating temperature range:	-20°C to +70°C
Relative humidity:	95% [100% intermittent]
Dimensions:	160h mm x 80w mm x 60d mm (without mounting bracket)
Weight:	1.6 kg (with bracket)
Enclosure:	Polycarbonate, self-coloured light grey
Mounting bracket:	Steel, zinc plated and passivated Stove light grey paint finish