



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 39	30-Aug-1989	Number 14	Issue date 26-Apr-2019	Valid until 30-Apr-2020

Page 1 of 2

Product designation

Viking, Model F-2, Water Motor Alarm

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Viking Fire Protection Supplies Pty Ltd
95 – 99 Hardys Road, UNDERDALE, SA, AUSTRALIA, 5032

Registrant

Viking Fire Protection Supplies Pty Ltd
95 – 99 Hardys Road, UNDERDALE, SA, AUSTRALIA, 5032

Producer

The Viking Corporation
210 North Industrial Park Drive, HASTINGS, MICHIGAN, UNITED STATES, 49058

Conformance criteria and evaluation

The Viking, Model F-2, Water Motor Alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories - Evaluation and listing, 'UL listing'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. The minimum working pressure is 34 kPa (5 psi).
- ii. The maximum allowable inlet water pressure is 1210 kPa (175 psi).

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 39	30-Aug-1989	Number 14	Issue date 26-Apr-2019	30-Apr-2020	

Producer's description

The Viking, Model F-2, Water Motor Alarm is a mechanical device actuated by a flow of water. It sounds a continuous alarm while a sprinkler system operates.

Technical specification

The following details are a representative extract of the technical specification for the Viking, Model F-2, Water Motor Alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Inlet thread	20 mm (3/4" NPT)
Outlet thread:	25 mm (1" NPT)
Dimensions:	Gong diameter 205 mm
Shipping weight:	4.1 kg

Supplementary information

The Viking, Model F-2, Water Motor Alarm is suitable for mounting to walls up to 356 mm thick. With a special Extension Staff, the alarm can be mounted on walls up to 762 mm thick.