



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 40</b>	30-Aug-1989	Number 14	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

## Product designation

**Viking, Models E-1/E-2, 80mm/100mm/150mm, Dry Pipe Valves**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Viking Fire Protection Supplies Pty Ltd  
95 – 99 Hardys Road, UNDERDALE, SA, AUSTRALIA, 5032

## Registrant

Viking Fire Protection Supplies Pty Ltd  
95 – 99 Hardys Road, UNDERDALE, SA, AUSTRALIA, 5032

## Producer

The Viking Corporation  
210 North Industrial Park Drive, HASTINGS, MICHIGAN, UNITED STATES, 49058

## Conformance criteria and evaluation

The Viking, Models E-1/E-2, 80mm/100mm/150mm, Dry Pipe Valves have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories - Evaluation and listing, 'UL listing'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. To be installed in vertical position only.
- ii. The maximum allowable inlet pressure is 1210 kPa (175 psi).

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to

## Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
<b>afp - 40</b>	30-Aug-1989	Number 14	Issue date 26-Apr-2019	30-Apr-2020	

### Producer's description

The Viking, Models E-1/E-2, 80mm/100mm/150mm, Dry Pipe Valves are latching differential valves used to separate the water supply from the dry pipe sprinkler system. The valves combine a positive latching clapper and air plate assembly, with a differential air to water seat design. The latching clapper and air plate assembly provides a positive mechanical seal for the air pressure in the dry pipe system while the differential design allows a moderate air supply to control a much higher water supply. When the air pressure is lowered sufficiently to destroy the pressure differential, the valve opens allowing the water to enter the dry pipe system. The Viking Accelerator can be used to speed the valve operation on large capacity systems or where faster action is required. The valves are also designed to operate a water motor alarm and/or an electric pressure alarm switch.

### Technical specification

The following details are a representative extract of the technical specification for the Viking, Models E-1/E-2, 80mm/100mm/150mm, Dry Pipe Valves and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

**Size:** 75 mm (E-2), 100 mm (E-2), 150 mm (E-1)

**Connection style:** Flanged inlet and outlet  
Flanged inlet, grooved outlet

Size	Friction loss <sup>(1)</sup>	Shipping weight
Flanged 80 mm	1.5 m	83 kg
Grooved 80 mm	1.5 m	87 kg
Flanged 100 mm	4.3 m	87 kg
Grooved 100 mm	4.3 m	83 kg
Flanged 150 mm	6.7 m	120 kg
Grooved 150 mm	6.7 m	112 kg

<sup>(1)</sup>Expressed in equivalent length of pipe C=120