



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 470</b>	15-Jan-1991	Number 13	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

## Product designation

**Tyco Fire Products, Model TY-B: SIN TY3151, 15NS thread x 8.1K(metric), 57°/68°/79°/93°/141°/182°C, 5 mm bulb, standard coverage, upright, standard response sprinklers**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Tyco Fire Protection Products  
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

## Registrant

Tyco Fire Protection Products  
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

### Producer

Tyco Fire Protection Products  
8902 North Interstate 27, LUBBOCK, TX, UNITED STATES, 79403

## Conformance criteria and evaluation

The Tyco Fire Products, Model TY-B: SIN TY3151, 15NS thread x 8.1K(metric), 57°/68°/79°/93°/141°/182°C, 5 mm bulb, standard coverage, upright, standard response sprinklers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories - Evaluation and listing, 'UL listing'.
2. Underwriters Laboratories Canada - Evaluation, follow-up services and listing, 'cUL listing'.
3. FMRC Document 0W1Q7.AF-16-January-1993, 'FMRC Document 0W1Q7.AF-16'.
4. Loss Prevention Council - Evaluation, surveillance and approval, 'LPC approval'.
5. Verband der Schadenverhütung - Evaluation and approval, 'Vds approval'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

(Limitations/conditions of conformance continue)

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



© CSIRO Australia, 2019

This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time.  
The validity and authenticity of this certificate can be verified by the certification register located at <http://www.activfire.gov.au>



This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
<b>afp - 470</b>	15-Jan-1991	Number 13	Issue date 26-Apr-2019	30-Apr-2020	Page 2 of 2

- i. Fire sprinkler equipment, system design and installation should be determined and verified in accordance with the performance and prescribed requirements of the regulations, standards and criteria as specified by the building code and authorities having jurisdiction. Due considerations include the occupancy fire loading, sprinkler location, coverage, response, hydraulic characteristics and other specified requirements relevant to the conformance and effectiveness of the equipment and installed system.
- ii. Specific or special requirements in relation to this product must be considered and included in the system design and installation.
- iii. Only the Style 10 or 20 recessed escutcheons are to be used for recessed installation.
- iv. The maximum working pressure is 1210 kPa.

## Producer's description

The Tyco Fire Products, Model TY-B: SIN TY3151, 15NS thread x 8.1K(metric), 57°/68°/79°/93°/141°/182°C, 5 mm bulb, standard coverage, upright, standard response sprinklers are designed for use in commercial occupancies such as banks, hotels, shopping malls, factories, refineries, chemical plants, etc.

The recessed version is intended for use in areas with a finished ceiling. It uses the two-piece Style 10 or Style 20 recessed escutcheon. The adjustment provided by the recessed escutcheon reduces the accuracy to which the fixed pipe drops to the sprinklers must be cut.

Corrosion resistant coatings, where applicable, are utilized to extend the life of copper alloy sprinklers beyond that which would otherwise be obtained when exposed to corrosive atmospheres. Although corrosion resistant coated sprinklers have passed the standard corrosion tests of the applicable approval agencies, the testing is not representative of all possible corrosive atmospheres. Consequently, it is recommended that the end user be consulted with respect to the suitability of these coatings for any given corrosive environment. The effects of ambient temperature, concentration of chemicals, and gas/chemical velocity, should be considered, as a minimum, along with the corrosive nature of the chemical to which the sprinklers will be exposed.

The glass bulb contains a fluid which expands when exposed to heat. When the rated temperature is reached, the fluid expands sufficiently to shatter the glass bulb, allowing the sprinkler to activate and water to flow.

## Technical specification

The following details are a representative extract of the technical specification for the Tyco Fire Products, Model TY-B: SIN TY3151, 15NS thread x 8.1K(metric), 57°/68°/79°/93°/141°/182°C, 5 mm bulb, standard coverage, upright, standard response sprinklers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

SIN	TY3151
Maximum working pressure	1210 kPa (175 psi)
Thread size	15NS (1/2" NPT)
Nominal K-factor	11.5 K(metric), l/min / kPa <sup>0.5</sup> (8.0 USGPM/psi <sup>0.5</sup> )
Nominal temperature rating	57°/68°/79°/93°/141°/182°C
Finishes	Natural brass, chrome plated, white polyester, lead coated, wax coated, wax over lead coated
Physical characteristics	
Frame	Bronze
Button	Brass/copper
Sealing assembly	Beryllium nickel w/Teflon
Bulb	Glass (5 mm)
Compression screw	Bronze
Deflector	Copper
Reference technical data sheet	TFP151, December 2007