



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 550	15-Mar-1992	Number 13	Issue date 26-Apr-2019	30-Apr-2020

Page 1 of 2

Product designation

Tyco Fire Products, Model ESFR-1: SIN TY6226, 20NS thread x 20.2K(metric), 74°/101°C, solder, storage, ESFR pendent, fast response sprinklers

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Tyco Fire Protection Products
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

Registrant

Tyco Fire Protection Products
Level 3, 95 Coventry Street, SOUTHBANK, VIC, AUSTRALIA, 3006

Producer

Tyco Fire Protection Products
8902 North Interstate 27, LUBBOCK, TX, UNITED STATES, 79403

Conformance criteria and evaluation

The Tyco Fire Products, Model ESFR-1: SIN TY6226, 20NS thread x 20.2K(metric), 74°/101°C, solder, storage, pendent, ESFR sprinklers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Underwriters Laboratories - Evaluation and listing, 'UL listing'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. The maximum allowable inlet pressure is 1210kpa (175psi).

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	Page 2 of 2
afp - 550	15-Mar-1992	Number 13	Issue date 26-Apr-2019	30-Apr-2020	

Producer's description

The Tyco Fire Products, Model ESFR-1: SIN TY6226, 20NS thread x 20.2K(metric), 74°/101°C, solder, storage, ESFR pendent, fast response sprinklers are intended to be used, for example, in the protection of open-frame single-row, double-row, multiple-row, and portable rack storage as well as palletized and solid- piled storage of most common materials.

The sprinklers, which produce a hemispherical discharge pattern below the deflector, are primarily designed for use with severe fire challenge installations. However, they may also be economical for use in the protection of ordinary storage.

Technical specification

The following details are a representative extract of the technical specification for the Tyco Fire Products, Model ESFR-1: SIN TY6226, 20NS thread x 20.2K(metric), 74°/101°C, solder, storage, ESFR pendent, fast response sprinklers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Actuating element:	Fusible link
Temperature ratings:	74°C, 101°C
Orifice size (nom):	20mm
K Factor (Metric):	20.6(l/min kPa)
Thread size:	3/4" NPT
Dimensions:	Length end to end - 103mm