



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 597	15-Mar-1992	Number 9	Issue date 30-Apr-2015	30-Apr-2016

Page 1 of 2

Product designation

Hochiki, Model ALB-E, high sens. photoelectric smoke detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Fire & Safety Products (A/Asia) Pty. Ltd.
41-45 Richmond Road, KESWICK, SA, AUSTRALIA, 5035

Registrant

Fire & Safety Products (A/Asia) Pty. Ltd.
41-45 Richmond Road, KESWICK, SA, AUSTRALIA, 5035

Producer

Hochiki Corporation
10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Conformance criteria and evaluation

The Hochiki, Model ALB-E, high sens. photoelectric smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.2-1990, 'Automatic fire detection and alarm systems - Point type smoke detectors'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 597	15-Mar-1992	Number 9	Issue date 30-Apr-2015	30-Apr-2016

Page 2 of 2

Producer's description

The Hochiki, Model ALB-E, high sens. photoelectric smoke detector is designed to operate in conjunction with an analogue fire detection system and as such is only compatible with specified equipment. The smoke detector is an addressable electronic device that provides analogue information for the Control & Indicating equipment to determine alarm status. The unique address of the smoke detectors is achieved using a binary code set by a dip switch in the base of the detector. When the detector is polled by the CIE it replies with an analogue value that represents smoke density.

In the alarm state, the LED on the base assembly is illuminated in a steady state. The indicating alarm can be reset with the removal of smoke and a reset function by the CIE.

Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model ALB-E, high sens. photoelectric smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Light source:	Infrared LED
Operating voltage:	18 to 27 Vdc
Current consumption:	0.35 mA (when not called)
Signal current:	
Reference	1.1 mA
Analogue	6 mA to 20 mA
Range	4 mA to 30 mA
Alarm current	10.5 mA max.
Diameter:	100 mm
Weight:	approx 90 g without base
Colour:	Off white

Tested base designation	Base + detector circuit type
Hochiki, Model YBF-RL/2NBF	Analogue Addressable