



Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|------------------|-------------------|-------------|---------------------------|-------------|
| afp - 658 | 13-Jan-1993 | Number 9 | Issue date 30-Apr-2015 | 30-Apr-2016 |

Page 1 of 2

Product designation

Hochiki, Model DCC-A, Type A heat detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Fire & Safety Products (A/Asia) Pty. Ltd.
41-45 Richmond Road, KESWICK, SA, AUSTRALIA, 5035

Registrant

Fire & Safety Products (A/Asia) Pty. Ltd.
41-45 Richmond Road, KESWICK, SA, AUSTRALIA, 5035

Producer

Hochiki Corporation
10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Conformance criteria and evaluation

The Hochiki, Model DCC-A, Type A heat detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.1-1990, 'Automatic fire detection and alarm systems - Heat detectors'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|------------------|-------------------|-------------|---------------------------|-------------|
| afp - 658 | 13-Jan-1993 | Number 9 | Issue date 30-Apr-2015 | 30-Apr-2016 |

Page 2 of 2

Producer's description

The Hochiki, Model DCC-A, Type A heat detector is provided with two thermistors which give two mode signals as rate of rise and fixed temperature using the Temperature vs Resistance characteristics of them and detects the thermal event of the fire.

Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model DCC-A, Type A heat detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

| | |
|--|---|
| Operating voltage: | 15 Vdc to 30 Vdc |
| Quiescent current: | 30 mA at 30 Vdc at 50°C |
| Maximum alarm current: | approximately 72 mA @ 30 Vdc approximately 34 mA @ 15 Vdc |
| Operating fixed temperature: | 58° - 88°C |
| Operating time for rate of rise action: | 2.5 min for 22°C/min rate of rise. Non-operation for a 6°C/min rate of rise at an air velocity of 1.2 m/s within 4.5 minutes |
| Mounting holes: | 48mm - 78mm in pitch |
| Weight: | approximately 80g without base |
| Colour: | White |

| Tested base designation | Base + detector circuit type |
|-----------------------------|------------------------------|
| Hochiki, Model YBF-RL/4AH4M | Conventional |
| Hochiki, Model YBC-R/3A | Conventional |
| Hochiki, Model AMU-MBM | Addressable |
| Hochiki, Model AMU-B2M | Addressable |
| Hochiki, Model YBF-RL/3JM | Conventional (Slave) |